



GOVERNMENT OF TAMIL NADU
DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

SANITARY CERTIFICATE

APENDIX – 3 (Chapter III Rule : 24)

I hereby declare that I have inspected

YOUNG INDIA PUBLIC SCHOOL
Run by YOUNG INDIA NOBLE FOUNDATION
NEXT TO ICHIPATTI POWER HOUSE (TNEB)
S.F. No.158/2A, 3A, CHINNA AYYAN KOVIL PIRIVU,
ICHIPATTI VILLAGE, PALLADAM TALUK,
TIRUPPUR – 641 668.

Building and premises on the day of 18.06.25 and certify

- The class room and surroundings are maintained neat and clean.
- The Sanitary arrangements provided are adequate and satisfactory.
- The drinking water arrangements provided is satisfactory.

This Certificate is issued subject to the following conditions

- The garbage generated within the School Premises should be collected and disposed off properly by appointing required Sanitary Staff.
- On any account, the garbage should not be burnt.
- The Children should be educated to prevent the usage of Plastics in the School premises and no one should bring plastic carry bags, use and throw Tumblers to the School.
- Fire precaution measures, and First Aid Box, should be provided.
- Every person in charge of place should be display and exhibit a board stating that the place is a “No smoking and No spitting place” and that “Smoking or spitting is an offence”
- This Certificate issued is liable to be cancelled at any time on infringement if any of the above said conditions and for improper maintenance of sanitation, improper maintenance of the building.
- This Sanitary Certificate valid one year only from the date of issue.**

BLOCK HEALTH SUPERVISOR

Government Primary Health Centre
Semmipalayam, Palladam Block
Tiruppur District

L.DIS. NO. 2762 /A4/2025 Dt. 18/06/2025
Countersigned

DISTRICT HEALTH OFFICER
TIRUPPUR



21
18-6-25



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,
Tiruppur – 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/4110	Report Issue Date :	12.12.2024
Invoice Details:	3076/Dt.09.12.2024/ Amt.Rs.1,652 /-		

Client Name & Address : M/s.Young India Public School,
Contact No / Email.ID : S.F.No:158/2A,3A,Next to ichipatti power house(TNEB),
Chinna Ayyan Kovil Pirivu,
Ichipatti, Tiruppur-641 668.

Sample Name : Water- Drinking
Sample Description : RO Water Outlet
Sample Code No : 4110
Sample Submitted by : Customer- Thiru.Jeevanandhan
Location & Date : M/s.Young India Public School & 09.12.2024
Quantity of sample Received : 2 Litre
Sample Container : Plastic – Good condition
Sample Condition on Receipt : Good
Sample Received On : 09.12.2024
Test Commenced on : 09.12.2024
Test Completed on : 10.12.2024
Environmental Condition : 23.0°C-27.0°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	IS 3025 Part 11-2022	--	8.10	6.5-8.5	6.5-8.5
2	Total Alkalinity as CaCO ₃	IS 3025 Part 23-2023	mg/L	11	200	600
3	Total Hardness as CaCO ₃	IS 3025 Part 21-2009 (RA:2023)	mg/L	9	200	600
4	Chloride as Cl	IS 3025-Part 32-1988 (RA:2019)	mg/L	9	250	1000
5	Sulphate as SO ₄	IS 3025-Part 24- Sec 1-2022	mg/L	4	200	400
6	Nitrate as NO ₃	IS 3025-Part 34- Sec 1-2023	mg/L	< 2	45	45
7	Fluoride as F	IS 3025-Part 60- Sec 1-2023	mg/L	< 0.2	1.0	1.5

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters.

..... End of the Report.....

Reviewd&Authorised Signatory
B .George - Junior Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue No./Date	01/01.07.2024	Amend. No/ Date	00/--	Page No	1 of 1
----------------	---------------	-----------------	-------	---------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,
Tiruppur - 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/4110	Report Issue Date :	12.12.2024
Invoice Details:	3076/Dt.09.12.2024/ Amt.Rs.1,652 /-		

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Physical observation	--	Clear	-	-
2	Colour	IS 3025-Part 4	Hazen	< 2	5	25
3	Odour	IS 3025-Part 5	--	Agreeable	Agreeable	Agreeable
4	Turbidity	IS 3025-Part 10	NTU	< 0.5	1	5
5	Total Dissolved Solids	IS 3025-Part 16	mg/L	38	500	2000
6	Conductivity	IS 3025-Part 14	μS/cm	54	-	-
7	P - Alkalinity as CaCO ₃	IS 3025-Part 23-1983	mg/L	NIL	-	-
8	Calcium as Ca	IS 3025-Part 40	mg/L	2	75	200
9	Magnesium as Mg	IS 3025-Part 46	mg/L	1	30	100
10	Iron as Fe	IS 3025-Part 53	mg/L	< 0.1	0.3	1
11	Manganese as Mn	IS 3025-Part 59	mg/L	< 0.05	0.1	0.3
12	Ammonia as NH ₃	IS 3025-Part 34	mg/L	< 0.1	0.5	0.5
13	Nitrite as NO ₂	IS 3025-Part 34	mg/L	< 0.01	-	-
14	Total Phosphate as PO ₄	IS 3025-Part 31	mg/L	< 0.1	-	-
15	Residual Chlorine	IS 3025-Part 26	mg/L	< 0.2	0.2	1.0
16	Fecal Coliform	IS 1622	CFU/100ml	0 / 100ml	0 / 100ml	0/100ml

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters.

..... End of the Report.....

Reviewd & Authorised Signatory
B .George - Junior Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue No./Date	01/01.07.2024	Amend. No/ Date	00/--	Page No	1 of 1
----------------	---------------	-----------------	-------	---------	--------