



GOVERNMENT OF TAMIL NADU
DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

SANITARY CERTIFICATE

APENDIX – 3 (Chapter III Rule : 24)

I hereby declare that I have inspected

**YOUNG INDIA PUBLIC SCHOOL
Run by YOUNG INDIA NOBLE FOUNDATION
NEXT TO ICHIPATTI POWER HOUSE (TNEB)
S.F. No.158/2A, 3A, CHINNA AYYAN KOVIL PIRIVU,
ICHIPATTI VILLAGE, PALLADAM TALUK,
TIRUPPUR – 641 668.**

Building and premises on the day of 18.06.25 and certify

- The class room and surroundings are maintained neat and clean.
- The Sanitary arrangements provided are adequate and satisfactory.
- The drinking water arrangements provided is satisfactory.

This Certificate is issued subject to the following conditions

- The garbage generated within the School Premises should be collected and disposed off properly by appointing required Sanitary Staff.
- On any account, the garbage should not be burnt.
- The Children should be educated to prevent the usage of Plastics in the School premises and no one should bring plastic carry bags, use and throw Tumblers to the School.
- Fire precaution measures, and First Aid Box, should be provided.
- Every person in charge of place should be display and exhibit a board stating that the place is a "No smoking and No spitting place" and that "Smoking or spitting is an offence"
- This Certificate issued is liable to be cancelled at any time on infringement if any of the above said conditions and for improper maintenance of sanitation, improper maintenance of the building.
- This Sanitary Certificate valid one year only from the date of issue.

Fr. A. J.
BLOCK HEALTH SUPERVISOR
Government Primary Health Centre
Semipalayam, Palladam Block
Tiruppur District

L.DIS. NO. 2762 /A4/2025 Dt. 18/06/2025
Countersigned

DISTRICT HEALTH OFFICER
TIRUPPUR

22
18-6-25





TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,
Tiruppur - 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com



TC - 15221

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

| | | | |
|------------------|------------------------------------|---------------------|------------|
| Sample / Lab No: | TR/2025/499 | Report Issue Date : | 29.11.2025 |
| Invoice Details: | 3226/Dt.27.11.2025/ Amt.Rs.1,652/- | | |
| ULR No: | TC1522125000000247F | | |

Client Name & Address : M/s. Young India Public School,
Contact No / Email.ID : S.F.158/2A,3A,Next to Ichipatti Power House(TNEB),
 Chinna Ayyan Kovil Pirivu, Ichipatti,
 Tiruppur- 641 668.

Sample Name : Water- Drinking
Sample Description : RO Outlet Water
Sample Code No : 499
Sample Submitted by : Customer- Thiru.Ragupathi.C
Location & Date : M/s. Young India Public School & 26.11.2025
Quantity of sample Received : 2 Litre
Sample Container : Plastic – Good condition.
Sample Condition on Receipt : Good
Sample Received On : 26.11.2025
Test Commenced on : 26.11.2025
Test Completed on : 27.11.2025
Environmental Condition : 23.0°C-27.0°C

| S.No | Parameters | Test Method | Unit | Result | Specification as per IS 10500 : 2012 | |
|------|---------------------------------------|--------------------------------|------|--------|--------------------------------------|--|
| | | | | | Acceptable Limit | Permissible Limit in the absence of alternate source |
| 1 | pH @ 25°C | IS 3025 Part 11-2022 | -- | 6.71 | 6.5-8.5 | 6.5-8.5 |
| 2 | Total Alkalinity as CaCO ₃ | IS 3025 Part 23-2023 | mg/L | 13 | 200 | 600 |
| 3 | Total Hardness as CaCO ₃ | IS 3025 Part 21-2009 (RA:2023) | mg/L | 10 | 200 | 600 |
| 4 | Chloride as Cl | IS 3025-Part 32-1988 (RA:2019) | mg/L | 13 | 250 | 1000 |
| 5 | Sulphate as SO ₄ | IS 3025-Part 24- Sec 1-2022 | mg/L | 14 | 200 | 400 |
| 6 | Nitrate as NO ₃ | IS 3025-Part 34- Sec 1-2023 | mg/L | < 2 | 45 | 45 |
| 7 | Fluoride as F | IS 3025-Part 60- Sec 1-2023 | mg/L | < 0.2 | 1.0 | 1.5 |

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters. End of the Report.....

Reviewed & Authorised Signatory
 B .George - Junior Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyan Complex, Avinashi Road,
Tiruppur - 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com

TEST REPORT


Doc.No: DWTL/FORM/7.8/01

| | | | |
|------------------|------------------------------------|---------------------|------------|
| Sample / Lab No: | TR/2025/499 | Report Issue Date : | 29.11.2025 |
| Invoice Details: | 3226/Dt.27.11.2025/ Amt.Rs.1,652/- | | |

| S.No | Parameters | Test Method | Unit | Result | Specification as per IS 10500 : 2012 | |
|------|-------------------------------------|----------------------|-----------|-----------|--------------------------------------|--|
| | | | | | Acceptable Limit | Permissible Limit in the absence of alternate source |
| 1 | Appearance | Physical observation | -- | Clear | - | - |
| 2 | Colour | IS 3025-Part 4 | Hazen | < 2 | 5 | 25 |
| 3 | Odour | IS 3025-Part 5 | -- | Agreeable | Agreeable | Agreeable |
| 4 | Turbidity | IS 3025-Part 10 | NTU | < 0.5 | 1 | 5 |
| 5 | Total Dissolved Solids | IS 3025-Part 16 | mg/L | 60 | 500 | 2000 |
| 6 | Conductivity | IS 3025-Part 14 | µS/cm | 86 | - | - |
| 7 | P - Alkalinity as CaCO ₃ | IS 3025-Part 23-1983 | mg/L | NIL | - | - |
| 8 | Calcium as Ca | IS 3025-Part 40 | mg/L | 1 | 75 | 200 |
| 9 | Magnesium as Mg | IS 3025-Part 46 | mg/L | 0 | 30 | 100 |
| 10 | Iron as Fe | IS 3025-Part 53 | mg/L | < 0.1 | 0.3 | 1 |
| 11 | Manganese as Mn | IS 3025-Part 59 | mg/L | < 0.05 | 0.1 | 0.3 |
| 12 | Ammonia as NH ₃ | IS 3025-Part 34 | mg/L | < 0.5 | 0.5 | 0.5 |
| 13 | Nitrite as NO ₂ | IS 3025-Part 34 | mg/L | < 0.01 | - | - |
| 14 | Total Phosphate as PO ₄ | IS 3025-Part 31 | mg/L | < 0.1 | - | - |
| 15 | Residual Chlorine | IS 3025-Part 26 | mg/L | < 0.2 | 0.2 | 1.0 |
| 16 | Fecal Coliform | IS 1622 | CFU/100ml | 0/ 100ml | 0 / 100ml | 0/100ml |

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters.

..... End of the Report....


28/11/2025
Reviewed & Authorised Signatory
B .George - Junior Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.